

Amendment-1 to the Tender dated 31/01/2019 for "Fire alarm, Fire fighting and Public addressing system works at New Circle office building, Rail Nilayam, Secunderabad".

It is decided to amend the following in respect of the above RFP:

SI. No.	Page No.	Clause No./ Item no.	Existing	Amended
1	148	1	Providing, laying, testing & Commissioning of following classes MS pipes conforming to IS 3589 and 1239 including fittings like elbows, tees, flanges, tapers, nuts, bolts, gaskets etc., complete. Makes: Jindal / Hissar / Tata pipes	Providing, laying, testing & Commissioning of following 'C' Class MS pipes conforming to IS 3589 and 1239 including fittings like elbows, tees, flanges, tapers, nuts, bolts, gaskets etc., complete. Makes: Jindal / Hissar / Tata pipes

All the other Instructions and Terms & Conditions of the above Tender remain unchanged. Please take note of the above Amendment while submitting your response to the subject Tender.

Date: 16/02/2019 Place: Hyderabad

Deputy General Manager