

BOQ FOR ELECTRICAL WORK OF CANARA BANK , KUAKHIA BRANCH & ON-SITE ATM

SL. NO.	DESCRIPTION OF ITEMS	UNIT	QNTY	RATE	AMOUNT
1. WIRING TO POINTS					
A	PVC conduit wiring				
1.0	Concealed conduit wiring to light, ceiling fan, exhaust fan points with (2x1.5 sq mm + 1(1x1sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 6 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge.				
	1. Primary (I light/fan controlled by one switch)	Nos.	13.00		
	2. Secondary point (2 lights controlled by 1 switch)	Nos	11.00		
	3. Primery point (wall/exhaust fan controlled by 1 switch and one 5 Amp. socket)	Nos	13.00		
	4. Primery point (ceiling fan controlled by 1 switch and electronic regulator)	Nos	2.00		
	5. Recess conduit wiring to 6 Amp plug socket with switch on existing board as above.	Nos.	3.00		
	6. Recess onduit wiring to Glow Sign Board point with timer & contactor controlling thro. A separate 16 Amp. DP MCB with metal enclosure complete.	Nos.	1.00		
2.0	Concealed conduit wiring to 6/16 Amp plug socket with switch on separate board with (2x1.5 sq mm + 1(1x1sqmm) PVC single core copper wire in PVC/ Super polyethylene pipe with galvanized iron junction & switch boxes & clip in type 6 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge at counter/table.	Nos	7.00		
3.0	Concealed conduit wiring to 20 Amp plug socket with switch on separate board with (2x2.5 sq mm + 1(1x1.5 sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 15 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge at strong room / cash counter.	Nos	3.00		
4.0	Supply and fixing of 1.5 meter length 3 core 2.5 sq.mm PVC insulated copper flexible cable with 3 pin 6A plug top at one end and the other end to be fixed with Switch Board of Strong Room and Locker Room.	Point	1.00		
5.0	Concealed conduit wiring to call bell point with one gong bell of 6" dia placed at strategic point with 6 Amp switch bell push clip in type modular type fixed on G.I. boxes placed at skirting level for emergency use, the wiring details are as per Sr .no. - 01. The places as located in drawing & as per direction of Engineer-in-charge.	SET	1.00		
6.0	Supply of all required materials and wiring to AC plug point with 2 (1x4sqmm) PVC insulated copper wire run inside screw type PVC conduit pipe with ISI market laid on surfaced / recessed of wall/celling alongwith 1 (1x2.5sqmm) PVC insulated copper wire as earth continuity conductor complete in all respect including with use of 1.0 TR AC starter, concealed metal boxes with cover, wire, 20A SPN metalclad plug socket, metallic switch box for plug, junction box etc complete with making good the damages caused as required and as per direction of Engineer in charge.	Nos.	1.00		
7.0	Supply , fixing , testing of phone point with suitable GI boxes with phone ,socket complete in all respect as per direction of EIC .	Nos.	4.00		

B	M.S conduit wiring in strong room				
1.0	Concealed conduit wiring to light, ceiling fan, exhaust fan points with (2x1.5 sq mm + 1(1x1sqmm) PVC single core copper wire in M.Sconduit with galvanized iron junction & switch boxes & clip in type 6 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge.				
	1. Primary (I light/fan controlled by one switch)	Nos.	5.00		
	2 .Recess conduit wiring to 6 Amp plug socket with switch on existing board as above.	Nos.	1.00		
	2. WIRING TO POINTS (U.P.S)				
1.0	Supplying & fixing of computer terminal boxes made of G.I. fitted with (2 nos. of 6 Amp switches + 4 nos. 6Amp socket), all clip in modular type & as per direction of Engineer-in-charge.	SET	9.00		
2.0	Supply of all required materials & wiring to clip in modular type 5 No. of 6/16 amp socket points controlled by 2 No of 16 amp switch with indicator complete in all respect including making good to damages caused as per direction of EIC for Hub connection / printer supply .	SET	1.00		
3.0	Concealed conduit wiring to 20 Amp plug socket with switch on separate board with (2x2.5 sq mm + 1(1x1.5 sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 15 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge at strong room / cash counter.	Nos	2.00		
4.0	Concealed conduit wiring to light point through UPS with (2x1.5 sq mm + 1(1x1sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 6 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge.				
	1. Primary (I light controlled by one switch in UPS at cash counter/ BM/ banking hall)	Nos.	3.00		
	3. WIRING . Main / Submain				
a	Providing and placing in position, testing and connecting 1.1 KV grade XLPE insulated PVC sheathed armoured Aluminium cable 3&1/2C x 35 sq. mm. conforming to IS 7098 with 2 Nos 10 swg GI ECC by GI bar and saddles on wall/floorpass. Cable to be from <u>Supply to Main DB.</u>	Mtrs.	50.00		
b	Providing and laying 4 x 6 sq. mm. FR PVC coated copper conductors (1.1 KV grade) in pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories from <u>Main DB to UPS DB.</u> Including all necessary terminals etc. complete.	Mtrs.	30.00		
c	Providing and laying 2 x 6 sq. mm. & 1 x 2.5 sq. mm. FR PVC coated copper conductors (1.1 KV grade) in pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories from <u>Main DB to INVERTER DB and then to LDB.</u> Including all necessary terminals etc. complete.	Mtrs.	50.00		
d	Providing and placing in position, testing and connecting 1.1 KV grade XLPE insulated PVC sheathed armoured Aluminium cable 4C x 10 sq. mm. conforming to IS 7098 with 2 Nos 10 swg GI ECC by GI bar and saddles on wall/floorpass. Cable to be from <u>Main DB to ATM ROOM.</u>	Mtrs.	50.00		

e	Providing and laying 4 core 6 Sq mm. Round Ar FR PVC insulated multi stranded copper cable in suitable size pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories for <u>AC DB/main Panel To Starters/Outdoor Units of cassette AC</u> . Including all necessary terminals etc. complete.	Mtrs.	40		
f	Providing and laying 2 x 2.5 sq. mm. & 1 x 1.5 sq. mm. FR PVC coated copper conductors (1.1 KV grade) in pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories from LDB to SWITCH BOARDS. Including all necessary terminals etc. complete.	Mtrs.	100		
g	Providing and laying 2 x 2.5 Sq mm. & 1 x 1.5 sq. mm. FR PVC insulated multi stranded copper wire in suitable size pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories for <u>UPS DB To Computer SB</u> . Including all necessary terminals etc. complete.	Mtr.	120.00		
h	Providing and laying 2 x 4 Sq mm. & 1 x 1.5 sq. mm. FR PVC insulated multi stranded copper wire in suitable size pvc rigid pipe/capping-casing on surface of wall duly clamping with necessary fittings and accessories for <u>Split AC</u> . Including all necessary terminals etc. complete.	Mtr.	15.00		
i	Supply of all required materials & laying of the following sizes of phone wires of approved make inside the approved size PVC conduit complete in all respect as per instruction of EIC . 2 pairs telephone wires	Mtrs.	60.00		
4. FITTINGS OF FIXTURES (A) Fitting Charges					
1.0	Installation and testing of recess LED light fittings (36 wt) of square type (2'-0"x2'-0") with all accessories complete required as per direction of Engineer in charge.	Nos.	8.00		
2.0	Installation and testing of recess LED light fittings (15 wt) of square type with all accessories complete required as per direction of Engineer in charge.	Nos.	4.00		
3.0	Installation and testing of recess LED spot light fittings (6 wt) of round type with all accessories complete required as per direction of Engineer in charge.	Nos.	9.00		
4.0	installation and testing of single T5 tube lights patty fittings (1x28wt) of surface mounting with all accessories complete required as per direction of Engineer in charge.	Nos	6.00		
5.0	Fitting of 450 mm sweep Wall fan of approved make .	Nos.	10.00		
6.0	Fitting of 1200 mm sweep Celing fan of approved make .	Nos.	2.00		
7.0	Fitting of 400 mm sweep Exhust fan of approved make .	Nos.	3.00		
8.0	Fitting of call bell of approved make .	Nos.	1.00		
9.0	Fitting of modular fan regulator of approved make .	Nos.	2.00		
10.0	Supply & fitting of Angle Holder with LED Light fittings (1x9wt) of surface mounting with all accessories complete as required as per direction of Engineer in charge.	Nos.	5.00		
11.0	Fitting and testing of flexibile LED strip of 5MTR of philips/Crompton/Wipro make along with electronic driver for30w flexi LED strip	Nos	9.00		
5. FITTINGS OF FIXTURES (B)					
1.0	Supply & fixing of fan-hook,by cutting roof slab and welding 10 mm dia.Fan hook with main re-Inforcemerit of roof slab complete in all respect.	Nos.	3.00		

6. MAIN PANEL & DISTRIBUTION BOARD.					
1.0	Supply, delivery, installation , testing , commissioning , of L&T indoor wall ,floor , mounted , type distribution boards made out of 2 mm thk. CR sheet metal duely acid treated premised & painted with 2 coats of enamel paint compartment arrangement for each equipment & bus bar chamber on the top of the panel running horizontal through out its length duly lamp , vermin proof having provision cable by conduit entry , earthling stud as per specification mentioned below duly factory wired confirming to the relevant ISS & as per special condition of contract , making good the damages M.S. Cubical type Panel board should have hinged door at the front. The panel shall be provided with all accessories & following arrangements complete in all respect & direction of EIC (before fabrication of panel board drawing is to be approved by Engineer-in-charge).	Set	1.00		
	Incoming- 1No 30KA - TPN SPD				
	1No 160A- 30KA - 4POLE -MCCB.				
	1 set of 125A TPN copper bus bar				
	1 set of 63 A TPN copper bus bar				
	63A, 4-POLE Change over				
	Out going- 2 Nos 32 A DP MCB for A.C				
	3Nos 32 A 4P MCB for Cassette A.C.				
	1Nos 63 A TPN MCB for A.T.M				
	1Nos 63 A4P MCB for U.P.S, 63A 4P MCB Spare				
	1Nos 40 A DP MCB for LDB/PDB 40A DP MCB Spare				
	1Nos 16/20A DP MCB for Glow sign board				
	1No. VAF Digital meter with CT.				
	6 Nos Phase indicator lamps				
2.0	Supplying & fixing of company made & wired with double door arrangement DB of approved make with following arrangement.(PREMIUM TYPE)				
a	L.D.B	Set	1.00		
	12 way SP DB				
	Incoming 1 No. 32A DP MCB				
	Out going 10 No. 6-10 A SP MCB				
b	C.D.B	SET	1.00		
	12 way SP DB				
	Incoming 1 No. 32A DP MCB				
	Out going 10 No. 6-10 A SP MCB				
c	U.P.S Incoming DB	SET	1.00		
	8 way SPN DB				
	40 Amp 4P MCB – 2 nos (1main & 1 spare).				
d	U.P.S Outgoing DB	SET	1.00		
	4 way SPN DB				
	40 Amp DP MCB – 2 nos. (1main & 1 spare).				
e	Inverter DB	SET	1.00		
	6 way SPN DB				
	40 Amp DP MCB – 3 nos. (1 incoming, 1 outgoing & 1 spare).				
f	U.P.S Changeover DB	SET	1.00		
	4 way SPN DB				
	2 nos of 40 Amp Change over (MCB type)				

7. EARTHING					
1.0	Earthing as per I.E. rules with 40mm dia G.I. pipe of 3 mt. Long perforated on all sides with arrangements of light , termination of 600x600x3mm copper plate & 19x3 G.I flat firmly connected to plate with copper nut & bolt , washer etc . The earth pit should be filled with alternate layers of charcoal, salt & soil. The brick masonry chamber is to be covered with CI cover of minimum 300mm x 300mm size with all accessories & as per direction of Engineer-in-charge. (Both the earth pit must be interconnected by earth flat)	Nos.	2.00		
2.0	Providing and fixing of chemical earth electrode made out of 50mm dia class-B Asahalock or equivalent 2m length with copper plate made out of 600x600x3.15 mm tinned copper plate along with one number 40x5mm tinned copper strip grazed with the plate buried vertically with top edge of the plate at a depth of 1500 mm with arrangements for termination of copper strip of earth continuity conductor including cost of charcoal, salt foreign soil, water pouring arrangements brick masonry enclosure on top with R.C.C cover complete with labour and material as per direction of Engineer-in-charge	SET	1.00		
3.0	The earth lead by 8sq.mm bare copper wire in GI pipe to connect from earth electrodes to UPS outgoing earth bus & as per direction of Engineer-in-charge.	Mts	60.00		
4.0	Supplying & fixing Earth lead with 8swc. of GI wire.	Mts.	80.00		
TOTAL (BRANCH ELECTRICAL WORK)					

BOQ FOR ELECTRICAL WORK FOR CNARA BANK , A.T.M AT KUAKHIA

1. WIRING TO POINTS				
1.0	Concealed conduit wiring to light, ceiling fan, exhaust fan points with (2x1.5 sq mm + 1(1x1sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 6 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge.			
	1. Primary (1 light/fan controlled by one switch)	Nos.	2.00	
	2. Secondary point (2 lights controlled by 1 switch)	Nos	2.00	
2.0	Supply of all required materials and wiring to AC plug point with 2 (1x4sqmm) PVC insulated copper wire run inside screw type PVC conduit pipe with ISI market laid on surfaced /recessed of wall/ceiling alongwith 1 (1x2.5sqmm) PVC insulated copper wire as earth continuity conductor complete in all respect including with use of 1.0 TR AC starter, concealed metal boxes with cover, wire, 20A SPN metalclad plug socket, metallic switch box for plug, junction box etc complete with making good the damages caused as required and as per direction of Engineer in charge.	Nos.	2.00	
3.0	Providing and fixing Glow Sign Board point with timer & contactor controlling thro. separate 16 Amp. DP MCB with metal enclosure complete.	Nos.	1.00	
2. WIRING TO POINTS (U.P.S)				
1.0	Concealed conduit wiring to 20 Amp plug socket with switch on separate board with (2x2.5 sq mm + 1(1x1.5 sqmm) PVC single core copper wire in PVC/ Super polythene pipe with galvanized iron junction & switch boxes & clip in type 15 Amp modular type switches with all accessories, T&P & as directed by the Engineer-in-charge . The point will be inside of back room of the ATM room.	Nos	2.00	
3. WIRING . Main / submain				
1.0	Supply of all required materials and wiring to circuits/ submains with following number and sizes of PVC insulated 1100 volt grade standard copper wire run inside pre-laid PVC conduit pipe of ISI mark as required and copper wire as earth continuity conductor and complete in all respect including making good to all damages caused and as per the direction of Consultant and Engineer-in-charge.			
A	Concealed wiring with 2x(1x2.5sqmm) +1x(1x1.5sqmm) copper wire	Mts	5.00	
B	Concealed wiring with 2x (1x4sqmm) + 1x (1x2.5sqmm) copper wire	Mts	10.00	
2.0	S & I of 1100V grade armoured cable having sector / circular shaped aluminium / copper conductor PVC insulated cores, laid up, PVC tape wrapped inner sheathed, GI strip / wire armoured and overall extruded PVC sheathed conforming to IS: 1554, laid on wall or ceiling using GI clamps and spacers as per route shown at site and further as directed by Bank / Architect in the following sizes.			
A	Concealed wiring with (6sqmm)3 1/2 core copper cable + 2x (1x4sqmm) copper wire. (for Cassette A.C./ U.P.S. input)	Mts	70.00	

3. FITTINGS OF FIXTURES (A) Fitting Charges					
1.0	Installation and testing of recess LED light fittings (15 wt) of square type with all accessories complete required as per direction of Engineer in charge.	Nos.	2.00		
2.0	Installation and testing of recess LED spot light fittings (6 wt) of round type with all accessories complete required as per direction of Engineer in charge.	Nos.	2.00		
3.0	Supply & fitting of Angle Holder with LED Light fittings (1x9wt) of surface mounting with all accessories complete as required as per direction of Engineer in charge.	Nos.	1.00		
4. DISTRIBUTION BOARD.					
1.0	Supplying & fixing of company made & wired with double door arrangement DB of approved make with following arrangement. (PREMIUM TYPE)				
a	L.D.B	Set	1.00		
	12 way SP DB				
	Incoming 1 No. 63A TPN MCB				
	Out going 2 No. 40A DP MCB for UPS, 2 No. 32A DP MCB for AC				
	2 No. 6-10 A SP MCB				
b	C.D.B	Set	1.00		
	8 way SP DB				
	Incoming 1 No. 40A DP MCB				
	Out going 3 No. 25 A DP MCB				
c	U.P.S Incoming DB	SET	1.00		
	4 way SPN DB				
	40 Amp DP MCB – 2 nos (1main & 1 spare).				
d	U.P.S Outgoing DB	SET	1.00		
	4 way SPN DB				
	40 Amp DP MCB – 2 nos. (1main & 1 spare).				
5. EARTHING					
1.0	Providing and fixing of chemical earth electroad made out of 50mm dia class-B Asahalock or equevalent 2m length with copper plate made out of 600x600x3.15 mm tinned copper plate along with one number 40x5mm tinned copper strip grazed with the plate buried vertically with top edge of the plate at a depth of 1500 mm with arrangements for termination of copper strip of earth continuity conductor including cost of charcole, saltoreign soil, water pouring arrangements brick massionry encloser on top with R.C.C cover complete with labour and material as per direction of Engineer-in-charge	SET	1.00		
2.0	The earth lead by 8sq.mm bare copper wire in GI pipe to connect from earth electrodes to UPS outgoing earth bus & as per direction of Engineer-in-charge.	Mts	20.00		
TOTAL (ATM ELECTRICAL WORKS)					

CANARA BANK, KUAKHIA BRANCH
SUMMARY OF B O Q FOR INTERIOR ELECTRICAL WORKS
SUMMARY OF TENDER

	TYPE OF WORKS	TOTAL
1	BRANCH INTERIOR ELECTRICAL WORK	
2	ON-SITE ATM ELECTRICAL & TELEPHONE WORKS	
	TOTAL	

* GST will be charge extra as applicable.