

Head Office: Bangalore

Amendment-1 to "COVJA/ P&E/ G-415/ 356/ 2018/ AS dated 20-03-2018 for TENDER FOR SITCM OF 2 SETS OF 2 NO'S 10 KVA UPS FOR RSTC & RO VIJAYAWADA from empanelled UPS vendors

It is decided to amend the following in respect of the above tender:

a. Technical Specification (Page 28 , Point 11)

Bank Requirements	Existing		Amended	
ISOLATION	a.Isolation of power	Appropriate mechanism like circuit breaker, MCB, MCCB etc., to disconnect the output of UPS, Input to UPS & battery bank must be included in the offer.	a.Isolation of power	Appropriate mechanism like circuit breaker, MCB, MCCB etc., to disconnect the output of UPS, Input to UPS & battery bank must be included in the offer.
	b.Manual service bypass switch	Should be provided.	b.Manual service bypass switch	Should be provided.
	NIL		c.Isolation Transformer	UPS output is isolated from mains input and battery (Galvanic Isolation Transformer)

All other terms and conditions of the above tender remain unchanged.

Please take note of above Amendments while submitting your response for above tender.

Date: 21-03-2018

Place: Vijayawada


Assistant General Manager

