

PREMISES & ESTATE SECTION
CANARA BANK, 2ND FLOOR, B WING,
BKC, CIRCLE OFFICE, BANDRA (E), MUMBAI
LL No.-022-26728463/8465; email-emcomcity@canarabank.com

Minutes of the pre-bid meeting held on 22/03/2018 for Supply, Installation, Testing and Commissioning of 1 number of 6-passenger capacity lift by dismantling the existing passenger lift, at Canara Bank RO North, Kohinoor building, Opp. Siddhivinayak Mandir, Prabhadevi, Mumbai- 25.

TENDER REF: 07/MECM/2018 DATED 16.03.2018.

MEMBERS PRESENT FROM BANK:

1. Shri Ashish Singh : Technical Field Officer
2. Shri Himanshu Vishwakarma : Officer

BIDDER'S REPRESENTATIVE PRESENT FROM:

1. M/s Otis Elevator Company India Ltd.
2. M/s Pace Elevators & Engg. Co. Pvt. Ltd.
3. M/s Escon Elevators Pvt. Ltd.
4. M/s Jolly Elevators Pvt. Ltd.
5. M/s Marconi Elevator Company

The Clarifications for the queries raised by the bidders and Corrigendum to certain clauses in tenders are enclosed herewith.

This Corrigendum shall form part of and shall be read with Tender / contract documents and shall become part of the contract and shall be signed on every page and enclosed with the bid.

In case of any discrepancy between this corrigendum and other tender / contract documents, the former shall prevail.

All the tender terms & conditions other than those modified in this corrigendum remain unchanged.

Yours Faithfully,


JYOTHILEKSHMI TP
DIVISIONAL MANAGER

TENDER REF. NO. 07/MCEM/2018 DATED 16/03/2018

Supply, Installation ,Testing and Commissioning of 1 number of 6-passenger capacity lift by dismantling the existing passenger lift, at Canara Bank RO North, Kohinoor building, Opp. Siddhivinayak Mandir, Prabhadevi, Mumbai- 25.

CORRIGENDUM TO TENDER DOCUMENT

S.NO.	Page No	CLAUSE No.	QUERIES IN BRIEF	REPLY TO QUERIES AND CLARIFICATIONS
1	18	Point No. 6 of General Conditions of Contract	Permits and Licenses	Deleted
2	41	Point No. 2 (ii) of Scope of work	Clarification regarding builder's work	Major civil works like plastering, painting, white wash, waterproofing, provision of granite door frame is not in supplier's scope. However, any Civil work required to facilitate the installation of lift (eg. civil works required for installation of rail) needs to be carried out by the Supplier.
3	46	Point No. 2.2.1 (b) of Scope of work	Clarification regarding lighting of elevator shaft	Elevator shaft lighting is not in supplier's scope.
4	49	Point No. 2.2.28 List of approved makes	Clarification regarding list of approved makes	Approved make or equivalent reputed make will be applicable.
5	56	Point E) Time schedule and completion milestone	Clarification regarding completion schedule	One hundred eighty days from the 14th day of award of work


Ashish Singh
TFO


Mahesh J Kholgade
MANAGER


Jyothilekshmi TP
DIVISIONAL MANAGER