

Replies to Pre-bid queries and Amendment-2 -> Re-Tender for COMPREHENSIVE CIVIL REPAIRS, PAINTING WORKS AND CONSTRUCTION OF TOILET BLOCK, CANARA BANK BEACH ROAD BRANCH, NO.55, TUTICORIN, TAMILNADU

Tender Ref No: CB: MDU: P&E:RO:TUT:02:2018 dated 08.08.2018

PAGE NO	S. No in BOQ	QUERY	REPLY
1	1	Use of GI sheet or Galvalume sheet instead of Green shade net	Since the site is near by seashore the windflow velocity is high. Use of GI Sheet or Galvalume sheet may be avoided. Hence Green shade net is recommended.
3	9	Unit for Treatment of plinth protection	As per Tender Document
5	17	Wall Crack Treatment is inclusive of plastering or not.	Cement mortar plastering is separate. But in this item rate to be inclusive of both side lime mortar rough plastering.
10	30	Main door - Glass thickness not mentioned	Glass to be used and its thickness is 10mm
13	37	Roofing puf sheet with old wooden rafters to be changed	As per Tender Document
Page No.26 in Revised BOQ	1 (e)	Reg. Purchase rate offer to be given in MT	As per Tender Document
		Permission from required govt. departments	To be obtained by the contractor

Date: 01.09.2018

sd/-
Divisional Manager
Canara bank, Premises & Estate Section
Circle Office, Madurai