

Replacement and shifting of LT panels, installing Rising Mains and other connected electrical works at Chennai circle office at 524, Anna Salai, Teynampet, Chennai 600018

Amendment-1 to Tender for Replacement and shifting of LT panels, Installing Rising Mains and other connected electrical works at Circle office.

Bid Details - NIO Clause 5,6,7

Events	Existing	Amended
	Date & Time	Date & Time
Period of issue of documents	10.06.2019	13.06.2019
Last Date of Submission of Tender	11.06.2019, 3.00 PM	14.06.2019, 3.00 PM
Opening of Tender	11.06.2019, 3.30 PM	14.06.2019, 3.30 PM

Other Clauses

Sl.No.	Bid	Page	Clause	Existing	Amended	Remarks
1	Technical Bid	3	NIT, Clause 4	EMD in Words: Rupees eighty thousand six twenty only	EMD in Words: Rupees eighty thousand only	-
2	Technical Bid	48	Technical Spec: 1. LT Switch Boards	The panel shall conform to IP-55	The panel shall conform to IP-42	-
3	Technical Bid	57	Technical Spec: 6. Power and Control cables	Steel Wire Armoured and XLPE Insulated	Steel Flat Armoured and XLPE (A2XFY and 2AXFY)	As per IS-7098-part-1
4	Technical Bid	62	List of Approved Make: 6. Rising mains	C&S, Schneider, L&T, Legrand	C&S, Schneider, L&T, Legrand, RR Kabel	Less Lead Time
5	Financial Bid	3	Item 1.1	Bus bar chamber consisting of TP and N bus bars rated 800 A made of electrolytic quality aluminium supported on SMC	Bus bar chamber consisting of TP and N bus bars rated 1250 A made of electrolytic quality aluminium supported on SMC	-
6	Financial Bid	6	Item 3.8, 3.9	Item Number 3.8, 3.9	Renamed as 3.7.1, 3.7.2	They are sub part of Item 3.7
7	Financial Bid	7	Item 7.1	Preparation of as-built drawing, getting drawing approval and conducting inspection by CEA and getting safety certificate	Preparation of as-built drawing, getting drawing approval and conducting inspection by CEA and getting safety certificate for the scope of work	CEA is applicable only for the work the contractor is executing as per this tender
8	Financial Bid	8	Item 9.2- 9.2.1, 9.2.2	MCB	MCCBs	
9	Financial Bid	8	Item 15	Disposal of Existing panels	Rates only to be quoted (QRO)	Rates will not be considered for L1

