

CORRINGENDUM FOR TENDER OF LIFTS FOR CIRCLE OFFICE BUILDING CHANDIGARH		
S.No	QUESTIONS	CLARIFICATIONS
1	Whether it is modernization with retention of some parts	Nothing to be retained. Replacement 100%.
2	Why bank needs work men compensation policy when a firm has ESI & PF for its workman. Either of the 2 will be permitted.	Either ESI or WCP
3	Retention money of 10% on final payment or contract value.	It is 10% of contract value
4	Modification of front Archid raver including RCC chipping on all 3 sides of the door. If any shall be done by Bank?	To be done by bank
5	Door opening failure rescue operation for man trapes other than power. The same safety factors should be incorporated. Bank to clarify.	Bank is not having such requirement. However vendor can offer at free of cost.
6	Since ARD (Automatic Rescue device) will work only if all 3Ø are not available. Wheather a new safety feature of nearest door operation for which rescue can be done.	As per existing terms & conditions mentioned in Tender.
7	"Duplex System with opposite constillation" can be installed ?	Bank require this feature.
8	Automatic releveilling to be provided ± 5 mm as per Indian standard	Bidder to ensure that the levelling of the Lift is as per IS i.e ± 5 mm.
9	"Door Nudging" to be provided. (Process by which door automatic closes after 4 time hindrances)	As per existing terms & conditions mentioned in Tender.
10	"Multibeam dooer detetdor" Minimum 150 beam to be provided.	As per IS Standards
11	"Arrival Chime" inside car ?	As per existing terms & conditions mentioned in tender.
12	"Load By Pass " feature that a lift can by paas floor.	Not mandatory. However bidder can provide at free of cost.
13	CCTV provision. If any company can provide CAT5 cable inside travelling cable.	CCTV mandatory & cat 5 wire as per bidder.

